

Monitoring Violations Annual Notice Template

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monitoring Requirements Not Met for City of Atlanta

Our water system violated several drinking water standards over the past year. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 4th quarter of 2022 we did not complete all testing for TTHM and HAA5 and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the contaminant(s) we did not properly test for during the last year, how often we are supposed to sample for these contaminants, how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date on which follow-up samples were (or will be) taken.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	When samples were or will be taken
TTHM	1	0	10/1/2022-12/31/2022	2/15/2023
HAA5	1	0	10/1/2022-12/31/2022	2/15/2023

What happened? What is being done?

Samples were collected by city employees during required time, but the testing did not get completed at the lab during required time. City staff re-sampled on Feb 15th, 2023 and lab results showed no contaminants. For more information, please contact Steve Westerfield at telephone number (309)-261-1529

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by the City of Atlanta.

Water System ID#

IL1070050

Date distributed

May 23, 2023